

AIRPORTS AUTHORITY OF INDIA
O/o MEMBER(PLANNING)


No. AAI/M(Plg.)/Tech.Inst./2008/1600

May 22, 2008

TECHNICAL INSTRUCTION No. 16.

CTE during inspection of work "providing design based air conditioning system for international and domestic terminal building at Calicut Airport", observed that the applications were invited from specialized agencies in central air conditioning system as per NIT. The design criteria was not spelled out in the NIT for the work based on the design. This has resulted in the issue of tenders to the firms without verifying their design experience.

Therefore, it is enjoined upon all concerned officials that the NIT for design based tenders shall be framed in such a manner that design experience is also sought along with the qualification criteria for issue of the tender.



(V. P. Agrawal)
Member(Planning)

Distribution as per attached list